

CHHATTISGARH STATE ELECTRICITY REGULATORY COMMISSION, RAIPUR

Order Sheet

Petition No:- 23/2026

Ultratech Cement Limited

--Petitioner

Versus

Chhattisgarh State Power Transmission Company Limited

Chhattisgarh State Power Distribution Co Ltd

--Respondent

Date of order or Proceeding	Order or proceeding with signature of presiding officer
31-07-2026 Web Copy	Shri Abhishek Munot and Shri Kunal Kaul, Shri Malcolm Desai counsels for petitioner M/s Ultratech Cement. Shri V.G. Ekka, SE for respondent CSPTCL. Smt. Alka Yadav, EE for respondent CSPDCL 2. The petitioner made their submissions in length with regards to the load enhancement of power drawl in a phased - wise manner pertaining to their Rawan Cement plant through dedicated 132 KV Suhela-Rawan transmission line from 220/132 KV Suhela Substations. 3. The petitioner also submits that the above enhancement shall be done without increasing their contract demand and the power that they will be drawing through open access shall be green power. Where as if need be the petitioner may increase their contract demand. 4. It is to be noted that the relevant suhela substation would require setting up of one 160 MVA, Transformer with regards to which the petitioner submitted that they alone shall not be forced to pay for such augmentation. 5. In light of these submissions both the respondents CSPDCL and CSPTCL are directed to submit a date wise schedule of load release/ catering plan against the proposed phase wise enhancement of the petitioner explaining technical feasibility for the same on notarized affidavit within two (02) weeks. 6. The case is listed for hearing on 21.08.2026 at 11:30 AM. Sd /- (Ajay Kumar Singh) Member (Tech.) Sd /- (Vivek Ganodwale) Member (Law)