Chhattisgarh State Electricity Regulatory Commission

"Vidyut Niyamak Bhawan"
Irrigation Colony, Shanti Nagar, Raipur (C.G.) – 492 001

Raipur, Dated June 16, 2025

No. D-19/CSERC/2025 - In exercise of powers vested under section 50, Section 181(2)(t) read with 181(2)(x) and the provisions of Section 43(1), 46, 47(1) and 47(4) read with Section 181(1), 181(2)(v) and 181(2)(w) of the Electricity Act 2003 the Chhattisgarh State Electricity Regulatory Commission (herein after, the Commission) has notified "Chhattisgarh State Electricity Supply Code-2011" (herein after, the Principal Code or Supply Code) and its first, second, third and fourth amendments.

The Ministry of Power, GOI, New Delhi, is identified certain changes in the Supply Code and other related Regulations for Ease of living. Accordingly, to incorporate those points for identified Ease of living the amendment in Supply Code is necessary.

The CSERC, in exercise of the powers vested in it under Clause 1.10 of the Supply Code, and in view of the above, amend the Supply Code.

Draft Chhattisgarh State Electricity Supply Code (Fifth Amendment), 2025

1. Short title and commencement:

1.1 This Code shall be called the "Chhattisgarh State Electricity Supply Code (Fifth Amendment) 2025".

1.2 They shall come into force with effect from the date of their publication in the official Gazette.

1.3 It shall extend to the whole of the state of Chhattisgarh.

1.4 All other words and expressions used in this Code, but not defined, shall have the same meaning as is in the Chhattisgarh State Electricity Supply Code, 2011 (herein after referred to as the principal Code).

2. In the Principal Code, Code 3.4 as previously substituted vide third amendment Code shall further be substituted, namely:

3.4 The supply voltage-wise minimum and maximum contract demands shall normally be as follows.

Supply Voltage	Minimum Contract Demand	Maximum Contract Demand
230 volts	-	5 KW*
440 volts	-	Up to 200 HP or 150 KW
11 KV	60 KVA	500 KVA
33 KV	60 KVA	15000 KVA
132 KV	4000 KVA	40000 KVA
220 KV	15000 KVA	150000 KVA

3. New code 4.1 (e) shall be added after Code 4.1 (d) of the Principal Code:

4.1 (e) In case of consumer wants to install roof top solar PV system of capacity not exceeding 10 KW, the following additional provision shall be applicable namely:

(i) No technical feasibility shall be carried out.

(ii) If the contract demand is less than capacity of roof top solar plant for which the consumer seeks to install, the contract demand shall be deemed to have been enhance to such extent.

(iii) In case where the contract demand of the consumer is enhanced as per the deemed provision under clause (b) the obligation of the consumer to bear the charges shall be as per the provision of the Supply Code.

(iv) The consumer shall be required to deposit additional security as per the provision.

4. New Proviso shall be added after Proviso in Code 4.20 (ii) of the Principal Code:

Provided further that any consumer, excluding domestic consumer, may avail separate LT/HT connection with suitable metering and metering equipment in same premises for EV charging/ setting up EV charging station.

5. The Code 7.16 (i) of Principal Code is substituted by following:

(i) Consumer may be permitted to change over to LT with connected load not exceeding 150 KW.

(S.P. Shukla)
Secretary